

# OF APPRECIATE

This is to certify that

# SUBUH ISNUR HARYUDO

has participated as

# PRESENTER

in ICOMERA 2018 (International Conference of Mechanical Engineering Research and Application 2018) at Santika Premiere Hotel, Malang, Indonesia from 23<sup>rd</sup> to the 25<sup>th</sup> of October 2018

ASSOC. PROF. AGUNG SUGENG WIDODO, Ph.D. Chairman ICOMERA 2018

COMP

ASSOC PROF. DJAROT B. DARMADI Ph.D. Head of Mechanical Engineering Department



#### **PAPER • OPEN ACCESS**

## Power Control of Grid-Connected Photovoltaic-Wind Turbin-Bouy Conversion Energy Wave Hybrid System

To cite this article: Subuh Isnur Haryuda et al 2019 IOP Conf. Ser.: Mater. Sci. Eng. 494 012074

View the article online for updates and enhancements.

#### You may also like

- Pieces of a puzzle: solar-wind power synergies on seasonal and diurnal timescales tend to be excellent worldwide Emmanuel Nyenah, Sebastian Sterl and Wim Thiery
- <u>The effect of particulate matter on solar</u> <u>photovoltaic power generation over the</u> <u>Republic of Korea</u> Junghoon Son, Sujong Jeong, Hayoung Park et al.
- A new approach for assessing synergies of solar and wind power: implications for West Africa Sebastian Starl Stafan Liersch Hanen

Sebastian Sterl, Stefan Liersch, Hagen Koch et al.



#### The Electrochemical Society Advancing solid state & electrochemical science & technology

## 242nd ECS Meeting

Oct 9 – 13, 2022 • Atlanta, GA, US Early hotel & registration pricing ends September 12

Presenting more than 2,400 technical abstracts in 50 symposia

The meeting for industry & researchers in

ENERGY TECHNOLOG







This content was downloaded from IP address 36.73.230.154 on 31/07/2022 at 15:37

### Power Control of Grid-Connected Photovoltaic-Wind Turbin-**Bouy Conversion Energy Wave Hybrid System**

#### Subuh Isnur Haryuda<sup>1\*</sup>, I Wayan Susila<sup>2</sup>, Indra Herlamba Siregar<sup>3</sup>, Aris Ansori<sup>4</sup>

<sup>1,2,3</sup> Mechanical Engineering Department, Universitas Negeri Surabaya, Indonesia. <sup>4</sup> Electrical Department, Universitas Negeri Suarabaya, Indonesia.

\*Corresponding author: subuhisnur@unesa.ac.id

Abstract. Problems in the provision of electrical energy in the coastal areas, such as electricity installation networks do not exist and the cost of making the system. This paper presents the results of design, optimization, and control of hybrid energy system of wave energy and wind energy and solar power. The ultimate goal is to design clean energy systems to meet the demand for electrical energy on the coast. The actual power system results from two renewable power systems: (1) Grid solar power system: Solar PV / wave energy / battery / inventer system; and (2) wind turbine / wave energy / battery / inventer system. The results show that Solar PV power systems / wave energy / battery / inventer systems offer better performance. The total energy generated by the solar power system can meet the AC load for the electricity needs of the household scale with almost no power shortage. The recommended system for coastal homes is economically and environmentally friendly with excess power (0.10%) and zero noise level.

Keywords: control, hybrid, solar PV, wind turbine, wave energy

#### I. Intorduction

Global energy needs have increased due to population growth, housing sector growth, industrial sector. The growth of world energy consumption, such as coal, natural gas and liquid fuels reached 78% of total consumption in 2040. [1]. The use of coal energy, natural gas, liquid fuels to fuel power plants used to supply electricity needs. Whereas in 2017 coal energy consumption (57.22%), natural gas (24.82%), liquid fuel (5.81%) and new and renewable energy (EBT) (12.5%) for generating fuel electricity [2]. The use of fossil fuels as a power plant increases CO2 production which has an impact on global warming and environmental pollution [3]. Solution to reduce the use of fossil fuels by using renewable energy sources for energy generation in remote areas or coastal coastal areas. Meanwhile, fulfillment of the need for electricity of around 1.2 billion people is still a problem, especially those living in remote areas, so pushing the fulfillment of electricity in remote areas continues to be driven by national or international institutions [4]. Indonesia is an archipelagic country that has a long coastline of 99,000 Km has the potential of renewable energy that has not been used optimally for energy sources of electricity generation in remote areas or in coastal areas. Meanwhile, East Java Province has no less than 79 small islands that are concentrated in the Madura Islands and a long coastline that covers the southern coast and north coast. The latest new energy potential (EBT) on the south coast can be used as an energy source for electricity generation.

The potential of renewable energy on the south coast of east Java stretches throughout the Pacitan, Tulungagung, Trenggalek, Malang, Lumajang, Jember and Bayuwangi regions. On average the latest new energy (EBT) on the coast of Malang Regency, such as wind energy with a speed of 2-6

Content from this work may be used under the terms of the Creative Commons Attribution 3.0 licence. Any further distribution of this work must maintain attribution to the author(s) and the title of the work, journal citation and DOI. Published under licence by IOP Publishing Ltd 1

IOP Conf. Series: Materials Science and Engineering 494 (2019) 012074 doi:10.1088/1757-899X/494/1/012074

m /s can be used as a driver of wind turbines, solar energy with an average of 4.8 Kwh/m<sup>2</sup> and wave energy with wave height around 1.5 to 2 meter that can be converted into electrical energy.

The implementation of hybrid power generation technology on the coast in Malang district as a source of electrical energy needs further research. Some obstacles to coastal renewable energy power generation, such as the continuous supply of electrical energy caused by weather and climate conditions, such as photovoltaic power plants can generate electricity during the day and the level of electricity production depends on changes in weather and climate. Meanwhile, wind turbine power plants depend on wind speed.

Power and energy management strategy for residential solar PV systems with Li-ion battery storage. Performance models for PV modules, small wind turbines, and Li-ion batteries with power smoothing applications, MAF is considered with two windows of average time of 5 and 15 minutes. In both cases, the desired smoothing effect is achieved, while the battery is worn around. 3.4 and 1.5 full cycles, each for summer and winter. Furthermore, batteries are used to maximize the use of renewable energy and minimize electricity bills, by minimizing energy purchased from utility networks. This is achieved by calculating a 15-minute average power curve for one full day, taking into account the load profile of the house and the renewable energy produced [5].

The PV / wind / diesel power plant model with the optimal configuration of the hybrid system is determined in terms of total system reliability (TED = 0%) and system costs, so that it is different from the results of optimal net present cost (TNPC), energy costs (EC), number of hours of operation, fuel consumption and the amount of CO2 emitted. PV / wind / diesel / battery hybrid systems were obtained for configuration with the lowest number of wind turbines (01 wind turbines) and the highest number of photovoltaic modules (53 PV modules) due to strong solar intensity. Simulation results show that PV / wind / diesel / battery options are more economical than using PV battery systems / wind // or diesel generators only [6].

Applications for solar PV hybrid power plants, wind energy and wave energy in the coastal waters of the tamban in malang district are expected to improve the performance of renewable energy power generation systems. While the amount of electrical energy produced can be calculated from the amount of energy of each system produced.

#### **1.1 Wave energy power generation**

The amount of power for wave energy power plants cannot be determined with certainty. Meanwhile, the calculation of wave energy power by calculating the wave period. Calculation of wave periods is calculated by Kim Nielsen's equation.

$T = 3,55 x \sqrt{h}$	(1)
with:	
T = wave period (sec)	
h = wave height (m)	
wavelength and wave velocity can be calculated by David Ross's equation.	
$\lambda = 5.12T^2$	(2)
with:	
$\lambda$ = wave length (m)	
the wave velocity is calculated by the equation.	
$V = \frac{\lambda}{\lambda}$	(3)
T	(0)
With, $v = wave speed (m/sec)$	
wave amplitude can be calculated by the equation	
h	
$a = \frac{1}{2}$	(4)
With, $h = wave height (m)$	

IOP Conf. Series: Materials Science and Engineering 494 (2019) 012074 doi:10.1088/1757-899X/494/1/012074

wave kinetic energy can be calculated by the equation.

$$PE = \frac{1}{4} w. \rho. g. a^2. \lambda(joule)$$

With,

a = wave amplitude (m)

w = wave width (m) = density of sea water (kg/m<sup>3</sup>)

 $g = earth's gravity (m/s^2)$ 

meanwhile, the electrical power generated from wave energy can be calculated by the equation.

$$Pw = \frac{PE}{T} (Watt) \tag{6}$$

While the power that can be transferred from wave energy can be calculated by the equation:

$P = \frac{\rho g^2}{64\pi} T_e h_e \cong 0.5 T_e h_e (KW/m)$	
---	--

With,

= density of sea water  $(kg/m^3)$ 

 $g = earth's gravity (m/s^2)$ 

 $T_e$  = wave period (sec)

 $h_e$  = wave height (m)

The energy calculated is in the direction of wave motion with the angle between the incoming wave and its direction, the density of wave energy can be calculated by the equation:

 $P_{\alpha} = P \cos(\alpha)$ 

#### 1.2 Solar PV power plant

Electrical energy generated from solar energy conversion with solar PV can be calculated equation;

 $\mathbf{P}_{\text{out}} = \mathbf{V}_{\text{oc}} \ x \ I_{sc}$ 

With,

P<sub>out</sub> = power of photovoltaic cells (watts)

 $V_{oc}$  = voltage open circuit (volts)  $I_{sc}$  = current flowing (ampere)

Solar PV efficiency is a ratio of solar energy that can be converted into electrical energy by photovoltaic cells. The amount of solar PV input energy can be calculated by measuring the amount of sunlight intensity with the solarmeter.

$$\eta = \frac{V_m I_m}{P_{solar}} = \frac{FF V_{oc} I_{Sc}}{P_{solar}}$$
(10)  
With, FF = fill factor

#### **1.3 Wind turbine power plants**

The principle of the conversion of wind energy to produce electricity in the power generation system is the kinetic energy of the wind to drive a wind turbine. The amount of kinetic energy (Ek) produced is determined by the velocity of the wind flow. Kinetic energy (Ek) wind can be calculated by the equation.

$$Ek = \frac{1}{2}m u_0^2$$
 (11)

With, m = mass of flowing wind (kg) IOP Publishing

(5)

(7)

(8)

(9)

4

IOP Conf. Series: Materials Science and Engineering 494 (2019) 012074 doi:10.1088/1757-899X/494/1/012074

 $u_0 = wind speed (m / s)$ 

Wind kinetic energy extracted by wind turbine blades is converted into mechanical energy. wind power that can be extracted by wind turbines from the Betz modeling, wind velocity  $u_0$  and density with sweeping area of the A<sub>1</sub> turbine rotor, can be calculated by the equation.

 $P_T = \frac{1}{2} C_p A_1 \rho u_0^3$ (12)Wind Power is the potential energy contained in the wind whose magnitude is the result of measurements of wind speed and specific data from the blades can be calculated by the equation.

 $P_{A} = 0.5 \rho U_{A}^{3} S$ with,  $U_A$  = wind speed kecepatan angin (m/det)  $U_A$  = wind speed kecepatan angin (m/det)  $\rho$  = air density (kg/m<sup>3</sup>)

Turbine power is energy that can be absorbed by a turbine from the wind which is the result of the calculation of the measured variables such as load, height and time. turbine power can be calculated by the equation.

 $P_T = T.\omega$ With,

 $P_T = power (watt)$ 

 $S = \text{Span Area} (\text{m}^2)$ 

T = Braking torque (N.m) $\omega$  = Turbine rotation (rps)

Turbine efficiency  $(C_P)$  is the ratio of power that can be absorbed by a turbine with wind power.

$$C_P = \frac{P_T}{P_A} \tag{15}$$

Turbine density ( $\sigma$ ) is the ratio of the turbine blade area to the turbine sweep area.  $\sigma = \frac{N.c}{D}$ (16)

With,

N = Number of blades

c = chord length (m)

 $P_e = \eta_g \eta_T \frac{1}{2} C_{p,\max} \rho A_2 v_1^3$ 

D = Diameter of the blade holder arm

Tip speed ratio ( $\lambda$ ) is the ratio of the speed of the rotor tip to the free wind speed, tip speed ratio will affect the rotational speed of the rotor

$$\lambda = \frac{\pi D n}{60 v}$$

The electrical power generated by the turbine obtained can be calculated by the equation.

#### 1.4 Grid-tied solar PV-wind turbin-wave energy power system

A hybrid system model that combines solar energy sources, wind energy and wave energy. The hybrid electrical network model can use several network models, such as; 1) the generator and battery systems are installed in a separate location and connected to the AC bus before connecting to the grid (figure 1), 2). The hybrid system converts the AC to DC voltage on the generator which produces AC power (figure 2), and 3). Hybrid system with electrical system with separate connections (figure 3)

**IOP** Publishing

(17)

(18)

(13)

(14)

Research and Application IOP Publishing

IOP Conf. Series: Materials Science and Engineering 494 (2019) 012074 doi:10.1088/1757-899X/494/1/012074







Figure 2. Hybrid model with DC to AC voltage converter used to feed to the grid (AC)



Figure 3. Hybrid system with separate network connection between plants

This study aims to test hybrid systems of solar PV power generation, wind energy and wave energy with model 1) grid solar PV power system: Solar PV / wave energy / battery / inventer system; and (2) grid wind turbine system: wind turbine / wave energy / battery / inventer system. It should be noted that two DC-coupling sources can be realized to utilize several power supplies at the same time.

#### 2. Research Method

We use experimental methods to determine the best way to assemble hybrid systems to improve the performance of solar PV power generation systems, wind turbines and wave energy, solar PV research instrument specifications for solar energy conversion of 100 Wp power capacity, wind turbines using H type wind turbines with the number of 6 blade blades to rotate the AC 3 phase 500 watt generator. Meanwhile, for wave energy conversion using a float model with a hydraulic system to rotate a 1 KW power 3 phase power generator.

The hybrid system model by combining power generation systems with AC power generated from wind turbines and wave conversion systems is converted into DC currents and fed to storage batteries, while channeling current to the grid in the form of AC electricity. The calculation of the electrical power produced by each generator by measuring the voltage and electric current produced, while the power that can be stored is done by measuring the battery capacity after filling the system



Figure 4. Research instrument a) Solar PV-wind turbin system, b)Wave energy conversion system, (c) Hybrid electrical model

#### 3. Results and Analysis

The results of the measurement of the potential of solar energy, wind and wave energy in the coastal areas of Malang Regency indicate energy sources that can be used as a source of renewable energy electricity generation. The potential value of solar energy intensity is an average in the energy range (100-822 w/m<sup>2</sup>) within 06.00-16.00, wind energy potential with wind speed range (0.3-5.5 m/s) within 06.00-19.00. while the potential for wave energy with a wave height (0.40-1.5 m).



Figure 5. Renewable energy potential in the coastal tamban

The level of stability and periodic range of energy, the source of wave energy has the same level of stability of energy. Meanwhile, solar and wind energy has very little energy stability and a short time span. Optimal use of solar energy from 06.00-16.00 with maximum energy for 3 hours at 822 w/m<sup>2</sup> at 11.00-13.00. Wind energy has a velocity range of 0.3-5.5 m / s which can rotate wind turbines well with good stability.



Figure 6. Electricity produced by solar PV, wind turbines and wave energy

The conversion of solar energy, wind energy and wave energy in the coastal area of the Malang Regency basin have a fluctuating level of electrical energy production based on the supply of available energy sources. Solar PV systems have a more optimal level of electricity production than system wind turbines. The electrical energy produced by Solar PV power systems / wave energy / battery / invaders produces an average power of 3,574 KW, while the wind turbine power system / wave energy / battery / inventer system produces 3,397 KW of power. While the average electricity consumption is 3,217 KW. The model of conversion system of coastal renewable energy Solar PV power systems / wave energy / battery / inventer is more peformace in the production of electricity compared to wind turbine / wave energy / battery / inventer with excess power (0.10%) and noise free. The system of Solar PV power systems / wave energy / battery / inventer as a power plant in coastal areas.

#### 4. Conclusion

Hybrid power plants with renewable energy sources of solar energy, wind energy and wave energy in coastal areas of the Malang district can be utilized to supply the electricity needs of the coastal communities. Solar PV systems have a more optimal level of electricity production than system wind turbines. Meanwhile, the incorporation of wave energy hybrid systems in solar PV systems and wind turbines results in the stability of different electrical energy production. Solar PV power systems / wave energy / battery / inventer generate an average power of 3.574 KW, while the wind turbine / wave energy / battery / inventer system model produces 3,397 KW of power. Models of Solar PV power systems / wave energy / battery / inventer are more peformace in the production of electrical energy compared to wind turbine / wave energy / battery / inventer systems with excess power (0.10%) and noise-free.

#### Acknowledgments

This research was supported by the national research incentive research program, funded by the Ministry of Research, Technology and Higher Education (No. 000005 / UN38.11-P / LT / 2018).

#### References

- [1] U.S. Energy Information Administration. International Energy Outlook 2018; Available602 from: http://www.eia.gov/forecasts/ieo/world.cfm (accessed 13.8.2018)
- [2] Kementrian Energi dan Sumber Daya Mineral (ESDM); from: <u>http://bisnis.com/amp/read/20180304/44/745790/pembangkit-listrik-bauran-batu-bara-57</u> (accessed 15.8.2018).
- [3] Wu Z, Xia X. Optimal switching renewable energy system for demand side management.604 Solar Energy 2015; 114: 278-288
- [4] Tazvinga H, Xia X, Zhang J. Minimum cost solution of photovoltaic-diesel-battery hybrid608 power systems for remote consumers. Solar Energy 2013; 96: 292-299.609
- [5] <u>B.N.PrashanthR, PramodG.B, VeereshKumar</u>. Design and Development of Hybrid Wind and Solar Energy System for Power Generation Materials today proceeding; <u>Volume 5, Issue 5,</u> Part 2, 2018, Pages 11415-11422
- [6] Abdelhamid Kaabeche a, Rachid Ibtiouen. Techno-economic optimization of hybrid photovoltaic/wind/diesel/ battery generation in a stand-alone power system. Solar Energy. 2014; 103 171–182
- [7] Hong Y, Lian R. Optimal sizing of hybrid wind/PV/diesel generation in a stand-alone power system using Markov-based genetic algorithm. IEEE Transactions on Power Delivery 2012;611 27(2):640-647